

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.
1

7300-0078:162

Page 1 of

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: ADEMCO, 165 Eileen Way, Syosset NY 11791
Contact: *Harry Pashkoff (516) 921-6704 Fax (516) 364-6953

DESIGN: Models 5881H, 5881M, and 5881L Receiver Modules. Models *5815, 5816, 5817 and 5827 Wireless Transmitters. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible household control units. Models 5801, *5815, 5816 and 5817 are for use with the following 3V lithium battery: ADEMCO Model 466, Panasonic Model CR123A, Sanyo Model CR123A or Duracell Model DL123A. Model 5827 is for use with the following 9V alkaline battery: ADEMCO Model 464, Duracell Model MN1604 or Eveready Model 522. Model 5803 is for use with the following non replaceable 3V lithium battery: Renata Model CR2032, Sanyo Model CR2032, Duracell Model CL2032 or Panasonic Model CR2032.

*Rev. 11-25-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

NOVEMBER 25, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager